

ADDENDUM No. 2

Goodwill Industries

High Point Upfit

April 15, 2019

Prepared for:



Goodwill Industries
Of Central North Carolina, Inc.

Prepared by:

MOOREHOCUTT
architects PLLC
ARCHITECTURE INTERIORS PLANNING

ADDENDUM NO. 2

Note: Bidder shall acknowledge receipt of Addendum No. 2 on Bid Proposal Form.

A. PROJECT ARCHITECTURAL SPECIFICATIONS

1. Any specifications that have a header indicating Morehead Urgent Care – West shall read Goodwill Industries High Point Upfit.
2. Replace prior Bid Form with attached revised Bid Form.

B. PROJECT DRAWINGS

1. Revise note 4 on sheet A1 to read “Install ceramic tile over new ½” moisture resistant drywall”.
2. Add note 18 on sheet A102 to read “Install one(1) 20A 120V duplex receptacle in ceiling adjacent to owner furnished cash wrap for ceiling hung monitor”. Monitor to be furnished and installed by owner.
3. Add note 19 on sheet A102 to read “Contractor shall caulk all acoustical ceiling wall mold prior to painting.
4. Add note 20 on sheet A102 to read “Provide alternate pricing to replace existing light fixtures in sales area, break room, dressing rooms, and office with 2x4 LED fixtures equal to Lithonia 2BLT4-60L-LP835-EZ1”.

C. CLARIFICATIONS

1. The dressing room benches shall be constructed of laminated ¾” plywood covered with plastic laminate of all sides and edges. Owner to select plastic laminate color.
2. Provide toilet room plumbing fixtures equal to the following:
 - Water Closet:
 - Manufacturer: American Standard
 - Model: Champion Pro-Model 3195a, 114225x.104
 - Seat: AMERICAN STANDARD 5901.110T
 - Urinal:
 - Manufacturer: American Standard
 - Model: Decorum 6042.005
 - Sink:
 - Manufacturer: American Standard
 - Model: Lucerne 0355.027
 - Faucet: 1340.225
3. Provide fiberglass mop basin equal to the following. Provide plumbing alteration as necessary.
 - Fiberglass Mop Basin:
 - Manufacturer: FIAT
 - Model: MSB2424
 - Faucet: 830-AA
4. New toilet partitions shall be solid phenolic type.
5. Bid Date is hereby extended until Tuesday, April 23, 2019 at 4:00pm.
6. We will not answer any questions after close of business on Tuesday, April 16, 2019.

END OF ADDENDUM NO. 2