


MEZZANINE PLAN



- GENERAL NOTES**
- EXISTING LIGHTING AS BASED ON EXISTING DOCUMENTS AND FIELD OBSERVATIONS. THE E.C. SHALL FIELD VERIFY ALL INFORMATION PRIOR TO BEGINNING WORK. BRING ANY DISCREPANCIES TO THE ENGINEER'S ATTENTION FOR DISPOSITION.
  - THE E.C. MAY REUSE EXISTING WIRING IN PLACE PROVIDED IT IS IN GOOD CONDITION AND MEETS THE REQUIREMENTS OF THE NEW CIRCUITS AS SHOWN ON E2.1.
  - MAINTAIN CONTINUITY TO CIRCUITS OR PORTIONS OF CIRCUITS FOR LIGHTING THAT IS EXISTING TO REMAIN. REFEED AS REQUIRED.
  - LIGHTING UNAFFECTED BY THE RENOVATION NOT SHOWN.

- KEY NOTES:** (XX)
- DEMOLISH EXISTING TRACED LEADS, BACK AND MOUNTING APERTURES. REMOVE CONDUITS, CONDUIT AND WIRING BACK TO SOURCE & COMPLETE.
  - FIELD IDENTIFY EXISTING COOLER / FREEZER LIGHTING. DISCONNECT AND REMOVE COOLER / FREEZER LIGHTING. PRESERVE CIRCUIT AND RECONNECT TO NEW COOLER FREEZER LIGHTING AS SHOWN ON E2.1.
  - REMOVE EXISTING FIXTURES TO NEW LOCATION SHOWN ON E2.1. EXTEND CONDUIT AND WIRING AS REQUIRED.
  - REPLACE EXISTING 100W HPS FIXTURE IN PLACE WITH NEW LED FIXTURE AS SHOWN ON E2.1.
  - REPLACE EXISTING WALL PACK FIXTURE IN SAME LOCATIONS WITH NEW LED WALL PACK FIXTURE. REMOVE SURFACE MOUNTED CONDUIT AND WIRING AND RELOCATED CIRCUIT AND WIRING TO INTERIOR OF THE BUILDING AS SHOWN ON E2.1.
  - DISCONNECT AND REMOVE EXTERIOR EGRESS FIXTURE. REMOVE WIRING BACK TO SOURCE.
  - REMOVE TOP OF CASE WALL WASH FIXTURES TO ALLOW FOR CASE REPLACEMENT. PRESERVE FIXTURES AND WIRING AND REINSTALL ON TOP OF NEW CASES AS SHOWN ON E2.1.

Design and Construction Documents are instruments of service as given in confidence and remain the property of Bondurant Associates, Inc. No part of these construction documents may be reproduced, stored in a retrieval system, or transmitted in any form or by any means without the written permission of Bondurant Associates.

Date: SEPTEMBER 10, 2019 Job No. 1922

Revisions:	No.	Date	By	Check

**BONDURANT ASSOCIATES**  
ENGINEERING & ARCHITECTURE  
444 CHAYKORS STREET  
PORTSMOUTH, VIRGINIA

**BRAND ENGINEERING, INC.**  
NC LICENSE NO. C-1504  
2840 POLO PARKWAY, SUITE 200  
MCKEITHAN, VA 23103  
PHONE: (804) 794-8588  
FAX: (804) 794-8588  
EMAIL: brand@brandeng.com


**Harris Teeter**  
Neighborhood Food & Pharmacy

Project: **HARRIS TEETER STORE #289 ~ REMODEL**  
2603 GLENWOOD AVENUE, SUITE 101  
RALEIGH, NC 27608  
Title: **LIGHTING DEMOLITION PLAN**

9/10/2019 3:04:41 PM

Order Plans @ [www.ldline.com](http://www.ldline.com)

**LIGHTING DEMOLITION PLAN**



SEAL  
228346  
9/10/19

NOTE: THIS DOCUMENT MAY HAVE BEEN ELECTRONICALLY TRANSMITTED. IF UNSIGNED, IT CANNOT BE FILED FOR PUBLIC RECORD. PUBLIC RECORD FILINGS REQUIRE SIGNED AND SEALED DOCUMENTS.