


MEZZANINE PLAN



- GENERAL NOTES**
- SEE SHEET E1.2 FOR LIGHTING FIXTURE SCHEDULE.
 - EXISTING LIGHTING SHOWN DASHED AND IN GRAYSCALE.
 - THE E.C. SHALL ALLOW FOR THE RELOCATION OF 5 ADDITIONAL 2X2 FIXTURES IN THE SALES AREA AS MAY BE DIRECTED BY THE HARRIS TEETER PROJECT MANAGER.

- KEY NOTES:**
- FIELD IDENTIFY EXISTING CIRCUIT SERVING COOLER / FREEZER LIGHTING TO BE REPLACED AND MARK PANEL SCHEDULE ACCORDINGLY. RELOCATE EXISTING CIRCUIT TO SERVICE NEW LIGHTING. RENEW CONDUIT AND WIRING AS REQUIRED FOR CONNECTION TO NEW LIGHTS.
 - RELOCATED FIXTURE, EXTEND CONDUIT AND WIRING TO EXISTING LOCATION TO LOCATION SHOWN.
 - CONNECT NEW FIXTURE TO EXISTING CIRCUIT SHOWN.
 - REPLACE EXISTING 100W HPS FIXTURE IN PLACE WITH NEW LED FIXTURE AS SHOWN. NO CHANGE TO CIRCUIT OR WIRING REQUIRED.
 - CONNECT NEW EXTERIOR EMERGENCY EGRESS LIGHT TO EXISTING CIRCUIT SHOWN. CONNECT FIXTURE TO UNSWITCHED PORTION OF CIRCUIT.
 - INSTALL NEW LED WALL PACK FIXTURES AT SAME LOCATION AS EXISTING. RELOCATE EXISTING SURFACE MOUNTED CONDUIT AND WIRING TO INTERIOR OF BUILDING.
 - INSTALL EXTERIOR EGRESS LIGHTING FIXTURE ABOVE DOOR AT THE SAME LOCATION AS THE EXISTING FIXTURE. CONNECT TO CIRCUIT SHOWN. CONNECT TO THE UNSWITCHED PORTION OF THE CIRCUIT.
 - REMOVE AND REINSTALL TOP OF CASE WALL WASH FIXTURES TO ALLOW FOR CASE REPLACEMENT. PRESERVE FIXTURES AND WIRING AND REINSTALL ON TOP OF NEW CASES.


WALK-IN COOLER / FREEZER LIGHTING LEVELS

LIGHT LEVELS IN WALK-IN COOLERS AND FREEZERS HAVE BEEN DESIGNED TO BE AT LEAST 108 LUX (10 FOOT CANDLES) AT A DISTANCE OF 75 CM (30 INCHES) ABOVE THE FLOOR, IN WALK-IN REFRIGERATION UNITS AND DRY FOOD STORAGE AREAS AND IN OTHER AREAS AND ROOMS DURING PERIODS OF CLEANING AND AT LEAST 540 LUX (50 FOOT CANDLES) AT A SURFACE WHERE A FOOD EMPLOYEE IS WORKING WITH FOOD OR WORKING WITH UTENSILS OR EQUIPMENT SUCH AS KNIVES, SLICERS, GRINDERS, OR SAWS WHERE EMPLOYEE SAFETY IS A FACTOR.

AREA OF WORK PLAN

REFERENCE SHEET C1.2 - AREA OF WORK PLAN FOR DELINEATION OF INDIVIDUAL WORK AREAS WITHIN THE PROJECT.

LIGHTING RENOVATION PLAN



NOTE: THIS DOCUMENT MAY HAVE BEEN ELECTRONICALLY TRANSMITTED. IF UNSIGNED, IT CANNOT BE FILED FOR PUBLIC RECORD. PUBLIC RECORD FILINGS REQUIRE SIGNED AND SEALED DOCUMENTS.

Design and Construction Documents are instruments of service and shall remain the property of Bondurant Associates, Inc. No part of these construction documents shall be reproduced, stored in a retrieval system, or transmitted in any form or by any means without the written permission of Bondurant Associates.

Date: SEPTEMBER 10, 2019 Job No. 1922

Revisions:	No.	Date	By	Check

BONDURANT ASSOCIATES
ENGINEERING & ARCHITECTURE
444 CHAWHORN STREET
PORTSMOUTH, VIRGINIA

BRAND ENGINEERING, INC.
NC LICENSE NO. C-1504
2840 POLO PARKWAY, SUITE 200
MCLEODHAM, VA 23103
PHONE: (804) 794-8588
FAX: (804) 794-8588
EMAIL: brand@brandeng.com

Harris Teeter
Neighborhood Food & Pharmacy

Project: **HARRIS TEETER STORE #289 - REMODEL**
2603 GLENWOOD AVENUE, SUITE 101
RALEIGH, NC 27608
Title: **LIGHTING RENOVATION PLAN**

Order Plans @ www.ldiline.com