MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

BOARD OF COUNTY COMMISSIONERS RESOLUTION R-696-09 (6/09)
BOARD AUTHORIZED ADMINISTRATIVE DIRECTION

NOTICE OF ACCEPTANCE (NOA)

Rankin Company
2900 St. Gregory Road
Grandview, MO 64030

Scope:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. You are hereby notified that you have reviewed and accepted by Miami-Dade County RER – Product Control Section, to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).
This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) have the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.
This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.
DESCRIPTION: Model EMS6230 Aluminum Louver
APPROVAL DOCUMENT: Drawing No. **09-0221.07-01** Sheets 1 thru 6 of 7, titled "EMS6230 Louver", sheets 1 through 7 of 7, dated 09/18/08, with revision D dated 04/28/2010, prepared by Rankin Company, signed and sealed by Theodore Hanson, P.E., bearing the Miami-Dade County Product Control revision stamp with the notation of Acceptance manner and signature done by the Miami-Dade County Product Control Section.
MISSILE IMPACT RATING: Large and Small Missile Impact Resistant
LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved," unless otherwise noted herein.
LIMITATION: This louver has not been evaluated for compliance with the impact testing standard ANSI/AMCA 540.
RENEWAL: of the NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code(s) affecting the performance of this product.
EXPIRATION OF THIS NOA: will cease after the expiration date or if there has been a revision or change in the materials, quality assurance or in the product's process. Misuse of this NOA, as to misrepresent the use of any product, by sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.
ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. Any mention of this NOA is displayed, then it shall be done in its entirety.
INSPECTION: A copy of this entire NOA shall be provided in the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.
This NOA consists of this page 1 and revision pages R-1 and R-2, as well as approved document mentioned above.
The referenced documentation was reviewed by Carlos M. Olivera, P.E.

NOA No. 10-0827.12
Expiration Date: August 25, 2015
Approval Date: October 20, 2010
Page 1

Rankin Company

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS
1. Drawing No. **09-0221.07-01** in 07Bs, titled "EMS6230 Louver", sheets 1 through 7 of 7, dated 09/18/08, with Revision D dated 04/28/2010, prepared by Rankin Company, signed and sealed by Theodore Hanson, P.E.

B. TESTS
1. Test reports on 11 Uniform Static Air Pressure Test, Loading per TDC TAN 2B0-94
5) Large Missile Impact Test per TDC TAN 2B0-94
10) Cyclic Wind Pressure Loading per TDC, TAS 202-94
along with marked-up drawings and details (Series designation of EMS6230 Aluminum Louvers), prepared by National Certified Testing Laboratories, Test Report No. NCTL-218-1624-01, dated 04/21/2010, signed and sealed by Daniel A. Peters, P.E.
"Grandfathered under NOA # 10-0622.04"
2. Test reports on: 1) 10-Minute Static Air Pressure Test, Loading per FBC/TAS 202-94
2) Large Missile Impact Test per TDC, TAS 201-94
3) Cyclic Wind Pressure Loading per TDC, TAS 202-94
along with marked-up drawings and details (Series designation of EMS6230 Aluminum Louvers), prepared by National Certified Testing Laboratories, Report No. 218-1630-1, dated 10/26/2010, signed and sealed by Daniel A. Peters, P.E.
3. Test report of Wind Driven Rain Resistance per TAS 100 (A)-95 for EMS6230 Aluminum Louvers, prepared by IRH Construction Materials Technologies, LLC, Test Report No. IRCW-0874-02-01, dated 05/27/2009, signed and sealed by Ron T. Ingram, P.E.

C. CALCULATIONS
1. Wind load louvers prepared by Rankin Company, dated 07/06/2010, signed and sealed by Theodore Hanson, P.E.
"Superseded under NOA # 10-0716.07"
3. Anchor verification calculations and structural analysis prepared by Rankin Company, dated 07/29/2011, signed and sealed by Chelsea G. Walsh, P.E.
"Superseded under NOA # 10-0622.04"
3. Anchor verification calculations and structural analysis, complying with FBC 2007, prepared by Rankin Company, dated 08/19/2010, signed and sealed by Daniel J. Rau, P.E.

Carlos M. Olivera, P.E.
Product Control Examiner
NOA No. 10-0827.12
Expiration Date: August 25, 2015
Approval Date: October 20, 2010

R-1

Rankin Company

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

D. QUALITY ASSURANCE
1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS
1. None.

F. STATEMENTS
1. Statement letter of code conformance to the 5th edition (2010) FBC and of no financial interest issued by Ted Bronner and Associates, LLC, dated 07/07/2010, signed and sealed by Theodore Hanson, P.E.

Carlos M. Olivera, P.E.
Product Control Examiner
NOA No. 10-0827.12
Expiration Date: August 25, 2015
Approval Date: October 20, 2010

R-2







«TABLE #1: APPROVED ATTACHMENTS»

STRUCTURE	CONNECTION TYPE	ANGLE SLOT WIDTH	SPACING	MIN. EMBEDMENT	MIN. EDGE DIST.	END DIST.
(12 GA MIN.) STEEL FRAMING	1/4"ø ASSY BOLT OR #12 - 14 SHEET. 2 SIDE	9/16"	3.5" MAX. C-C	N/A	1"	2.5"
2" MIN.) CONCRETE (4000 PSI MIN.)	3/8"ø HILTI KB II, ANCHOR	3/4"	8" MAX. C-C	2"	4"	4" MIN.
CONCRETE FILLED CMU	3/8"ø HILTI KB II ANCHOR	3/4"	8" MAX. C-C	2.5"	4"	4"
(2" – 2 1/2") WOOD FRAMING (MIN. S.G. = 0.55)	5/16"ø X 3" ASSY LOW SCREW	7/16"	6" MAX. C-C	1"	2 1/2"	2.5"

NOTE: ALL OPENINGS MUST BE REPAIRED PER THE MANUFACTURER'S MIAMI-DADE COUNTY APPROVED INSTALLATION INSTRUCTIONS

TABLE #2: DRAWING CROSS REFERENCE

ITEM	DRAWING	MATERIAL	DESCRIPTION	RUSKIN #
1	09-0221.07-05C	6063-T6 AL	HEAD FRAME	70-021986-000
2	09-0221.07-03C	6063-T6 AL	SILL	70-021988-000
3	09-0221.07-05D	6063-T6 AL	SILL FRAME	70-022627-000
4	09-0221.07-05A	6063-T6 AL	JAMB FRAME	70-022627-000
5	09-0221.07-04C	6063-T6 AL	SUB ANGLE (WITH STIFFENERS)	–
6	09-0221.07-04A	6063-T6 AL	SUB ANGLE CONCRETE STRUCTURES	–
7	09-0221.07-04B	6063-T6 AL	CLIP ANGLE (WOOD STRUCTURE)	–
8	09-0221.07-04D	6063-T6 AL	DOWEL CLIP ANGLE (STEEL STRUCTURE)	–
9	09-0221.07-04E	6063-T6 AL	CONC. CLIP ANGLE (CONCRETE STRUCTURE)	–
10	09-0221.07-03B	6063-T6 AL	FRNT. S.S. ANGLE (WOOD STRUCTURE)	–
11	09-0221.07-07B	3003-H14 AL	HEAD/SILL CRAFT PLATE (DRY STRUCTURE)	–
12	09-0221.07-07C	3003-H14 AL	HEAD/SILL CRAFT & PLATE (WET STRUCTURE)	–
13	09-0221.07-07D	3003-H14 AL	JAMB & CLOSE OUT STRUCTURES	–
14	09-0221.07-07E	SST 316L/304	CONC. TO ENCAPSULATE PLATE (NON-STRUCTURE)	–
15	09-0221.07-07F	3003-H14 AL	JAMB TAB (WOOD STRUCTURES)	–







Order Plans @ WWW.LDLine.com

PRODUCT APPROVAL - LOUVERS

A1 NTS

FleischmanGarcia
ARCHITECTS · PLANNING · INTERIOR DESIGN
SARASOTA OFFICE
2905 CATTLEMEN ROAD, SUITE 300
SARASOTA, FLORIDA 34232
941.342.8223
FAX (941) 342-8223
TAMPA OFFICE
351 HYDE PARK PLACE, SUITE 300
TAMPA, FLORIDA 33606
813.251.1994
FAX (813) 251-1994
REGISTERED FIRM NUMBER AA C000321

Pasco County
Fire & Rescue Station
No. 17
New Port Richey, Florida

THIS DESIGN AND DRAWING IS THE SOLE PROPERTY OF FLEISCHMAN GARCIA AND IS PART OF THIS WORK MAY NOT BE COPIED WITHOUT PRIOR WRITTEN PERMISSION FROM FLEISCHMANGARCIA

I CERTIFY TO THE BEST OF MY KNOWLEDGE THAT THIS DRAWING COMPLY W/ ALL RELEVANT BUILDING CODES

FGA PROJECT NUMBER
19039

ISSUE DATE
05-25-20

SHEET NUMBER
PA-11

05-27-20 Jeff Petzschke\2019\19039_Pasco FS 17\Dwgs\Sheets\Product Approval\19039_PA-11.dwg